

Rapor Detayı 1

Partikül Ölçümü

PARTİKÜL SAYIMI RAPOR DETAYI

Tarih : 25.01.2018

Uygulayan : Ali YILDIZ
Makine Mühendisi

İmza :

ODA ADI	ORT 0.5 μ (1 m ³)	ORT 5.0 μ (1 m ³)	Kriter 0.5/5.0 μ maksimum adet	Kritere Uygunluk
B BLOK AMELİYATHANE - 1	51.717	1.547	352.000/2.930	Uygun
B BLOK AMELİYATHANE - 2	189.400	1.502	352.000/2.930	Uygun
B BLOK AMELİYATHANE - 3	20.848	972	352.000/2.930	Uygun
B BLOK AMELİYATHANE - 4	35.336	265	352.000/2.930	Uygun
B BLOK AMELİYATHANE - 5	6.626	0	352.000/2.930	Uygun
B BLOK AMELİYATHANE - 6	159.576	442	352.000/2.930	Uygun
B BLOK AMELİYATHANE - 7	8.834	1.237	352.000/2.930	Uygun
B BLOK AMELİYATHANE - 8	9.100	0	352.000/2.930	Uygun

Tespit

--

ONAY

ATSON		Tarih : 02.03.18	İmza: 
ALARKO CARRIER SAN. VE TİC. A.Ş. / ANKARA		Tarih :	İmza:
TRABZON FARABI HASTANESİ / TRABZON		Tarih :	İmza:

PARTİKÜL SAYIMI RAPOR DETAYI

Tarih : 25.01.2018

Uygulayan : Ali YILDIZ
Makine Mühendisi



İmza :

ODA ADI	ORT 0.5 µ (1 m ³)	ORT 5.0 µ (1 m ³)	Kriter 0.5/5.0 µ maksimum adet	Kritere Uygunluk
B BLOK AMELİYATHANE - 9	94.965	0	352.000/2.930	Uygun
B BLOK AMELİYATHANE - 10	3.622	0	352.000/2.930	Uygun
B BLOK AMELİYATHANE - 11	101.679	1.149	352.000/2.930	Uygun
B BLOK AMELİYATHANE - 12	2.827	354	352.000/2.930	Uygun
B BLOK AMELİYATHANE - 13	263.322	71	352.000/2.930	Uygun
B BLOK AMELİYATHANE KORİDOR	204.771	6.302	3.520.000/29.300	Uygun
B BLOK AMELİYATHANE UYANDIRMA	176.384	2.414	3.520.000/29.300	Uygun

Tespit

--

ONAY

ATSON		Tarih : 02.02.18	İmza: 
ALARKO CARRIER SAN. VE TİC. A.Ş. / ANKARA		Tarih :	İmza:
TRABZON FARABI HASTANESİ / TRABZON		Tarih :	İmza: